



The State of New Hampshire
Department of Environmental Services



Michael P. Nolin
Commissioner
December 31, 2003

Cumberland Farms Inc.
ATTN: Richard Etzold
777 Dedham Street
Canton, MA 02021

**NOTICE OF NON-COMPLIANCE and
PERMIT REVOCATION – NCPR # 03-026**

RE: CLAREMONT, SAM'S FOOD STORE (CF# 2839), EXISTING UNDERGROUND
STORAGE TANK FACILITY (UST #A-0110747) (DES #199812210)

Dear Mr. Etzold:

The New Hampshire Department of Environmental Services ("DES") is hereby notifying you that the above-referenced facility, located at 358 Washington Street, Claremont, NH is not in compliance with New Hampshire Code of Administrative Rules Env-Wm 1401, regulating Underground Storage Facilities. On September 8, 2003 a DES inspector conducted a compliance audit at the facility. A written document, describing the deficiencies was provided to the facility representative. This document required the facility be returned to compliance within 45 days, and DES be notified of the corrective measures taken. Compliance has not been achieved. **Failure to achieve compliance with the following deficiencies within 90 days from the date of this Notice of Non-Compliance and Permit Revocation ("Notice") will result in revocation of your Permit-to-Operate on March 30, 2004. This letter contains important compliance and procedural information. Please read it carefully.**

Env-Wm 1401.30 Release Detection for Piping

Env-Wm 1401.30 requires all pressurized piping without secondary containment and leak monitoring to be monitored for releases. DES has determined that the annual tightness test documentation for the piping was not available. Piping tightness test results for all piping must be provided to DES

2. Env-Wm 1401.32 Corrosion Protection for Steel Tanks

Env-Wm 1401.32 requires corrosion protection systems be tested within six (6) months of installation and every three (3) years thereafter. Also, monitors for impressed current systems shall be inspected every 60 days to ensure equipment is running properly. DES has determined that documentation showing that the monitors for impressed current systems have been inspected every 60 days was not available. Provide documentation showing that the monitors for the impressed current system have been inspected every 60 days for all piping systems.

3 Env-Wm 1401.33 Corrosion Protection for Piping

Env-Wm 1401.33 requires corrosion protection be installed on regulated piping prior to December 22, 1998. DES has determined that the corrosion (cathodic) protection system was not operational; therefore, the system must be repaired or permanently closed. Provide corrosion protection repair documentation or notify DES that the tank systems are temporarily closed and will be permanently closed.

In addition, Env-Wm 1401.10(a) requires owners of underground storage facilities for oil to maintain financial responsibility for costs associated with cleanup of releases from systems, the implementation of corrective measures, and compensation for third party damages in the amount equal to or greater than \$1,000,000 per occurrence. Env-Wm 1401.10(c) provides that the financial responsibility requirement may be satisfied if the owner is eligible for reimbursement of costs associated with cleanup of releases from the Oil Discharge and Disposal Cleanup Fund ("the Fund"). Eligibility for the Fund is contingent upon achieving and maintaining compliance with statutory (RSA 146-C) and regulatory (Env-Wm 1401) requirement. This facility has not achieved compliance, consequently, the Fund is not available to you as a financial responsibility mechanism.

In accordance with RSA 146-C:4 and Env-Wm 1401.07(a), no person shall own or operate an underground storage facility without a permit issued by DES. Within 30 days from the date of the permit revocation the facility shall be closed in accordance with Env-Wm 1401.18 for permanent closure.

Based on the compliance deficiencies described above, DES believes this facility poses a potential substantial threat to the surface and groundwater of the state. Therefore, in accordance with RSA 146-C:4 and Env-Wm 1401.09, if compliance as requested above is not achieved within ninety (90) days of the date of this Notice your Permit-to-Operate (UST Permit #0110747) shall be revoked effective **March 30, 2004**. Within thirty (30) days of the date of permit revocation all regulated substances must be removed from the UST systems at this facility. If the facility achieves compliance during the ninety (90) day period, it is necessary that documentation be submitted to DES verifying that compliance has been attained.

You have the right to a hearing to contest these allegations before the proposed license action is taken. The hearing would be a formal adjudicative proceeding pursuant to RSA 541-A:31, at which you and any witnesses you may call would have the opportunity to present testimony and evidence as to why the proposed action should not be taken. All testimony at the hearing would be under oath and would be subject to cross-examination. If you wish to have a hearing, one will be scheduled promptly.

RSA 541-A:31 III(e) provides that you have the right to have an attorney present to represent yourself at your own expense. If the Permit is an occupational license, under RSA 541-A:31, III(f) you have the right to request DES to provide a certified shorthand court reporter

NOTICE OF NON-COMPLIANCE and PERMIT REVOCATION – NCPR # 03-026

December 31, 2003

Page 3 of 4

at your own expense. **Such request must be submitted in writing at least 10 days prior to the proceeding.**

You may waive your right to a hearing. If you waive the hearing, DES is prepared to proceed with the actions as stated above. You should notify DES of your decision by filling out and returning the enclosed form.

If there are any questions concerning the above, I may be contacted at the Waste Management Division at (603) 271-1165.

Sincerely,

A large, bold, black 'COPY' stamp is overlaid on the signature.

Lynn A. Woodard, P.E.

Supervisor

Oil Compliance and Initial Response Section

CERTIFIED MAIL # 7000 1670 0000 0585 2061

cc: Michael P. Nolin, Commissioner
Mark Harbaugh, DES Legal Unit
Fred McGarry, P.E., Chief Engineer, WMD
George Lombardo, P.E., WMD
Tom Beaulieu, WMD
Health Officer, City of Claremont